

CERTIFICATE

Certificate No.: PL 4603717 001
Project No.: 89211773

Holder: Plinten & Profielen Centrale B.V.
Weegmaat 3
3961 NN Wijk bij Duurstede
The Netherlands

Product : **Underlayment: PPC ondervloerplaat 10 dB**
Total thickness : 10.0 mm
Total mass : 2350 gr/m²

Certified in combination with : Floorcovering: 8 mm click laminate.

On basis of the results of the tests specified below, we declare that the above specimen fulfils the requirements of the TÜV Rheinland Testmark **Noise Reduction** including **Regular Product Surveillance**. TÜV Testmark and Underlayments, Test Protocol Impact Sound – 2017 EV

NB: This certificate itself shall not be considered as a type examination certificate.

Performance properties	Requirement	Result
Impact sound improvement according ISO 10140 and ISO 717-2	$\geq 10 \text{ dB } \Delta L_{\text{lin}}$	Pass

Full details of the results can be found in the following report(s):

Reference	Date of issue	Result
Initial test report: A 2393-3E-RA-002	December 2014	10 dB ΔL_{lin} & 21 dB ΔL_w

Arnhem, 22-5-2017


C.C.M. van Houten, Manager operations
Page 1 of 1